



Amerang



Schonstett



Eiselfing

Entwicklung der Nitratwerte im Verbandsgebiet

	<u>Brunnen Schonstett</u>	<u>Brunnen Wimpasing 2</u>	<u>Brunnen Wimpasing 1</u>	
1999	18,00	22,00	18,00	mg/l
2001	21,00	22,50	21,00	mg/l
2002	18,00	23,00	22,00	mg/l
2003	16,40	23,00	23,00	mg/l
2004	16,90	22,00	22,80	mg/l
2005	17,60	23,40	22,50	mg/l
2006	21,30	26,70	26,70	mg/l
2007	18,90	23,80	23,20	mg/l
2008	20,00	24,70	25,10	mg/l
2009	20,90	27,90	27,00	mg/l
2010	17,30	27,20	24,80	mg/l
2011	18,70	26,60	25,20	mg/l
2012	17,20	26,20	24,80	mg/l
2013	18,10	30,10	28,00	mg/l
2014	18,20	28,10	28,20	mg/l
2015	17,20	26,50	25,10	mg/l
2016	16,40	28,60	27,40	mg/l
2017	16,80	27,80	25,30	mg/l
2018	16,60	25,90	25,80	mg/l
2019	16,00	25,70	23,30	mg/l

Der Grenzwert laut Trinkwasserverordnung liegt bei **50 mg/l**.

